



CERT

DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NG-4390BM0278

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	WITT GmbH & Co. Holding & Handels KG Salinger Feld 4-8, D-58454 Witten
Distributor <i>Vertreiber</i>	WITT-Gasetechnik GmbH & Co. Produktions- und Vertriebs KG Salinger Feld 4-8, D-58454 Witten
Product Category <i>Produktart</i>	gas fittings: Gas back flow safety device (4390)
Product Description <i>Produktbezeichnung</i>	non-return valve for natural gas by combustion with air, without additional flame arrestor
Model <i>Modell</i>	Modell 339
Test Reports <i>Prüfberichte</i>	laboratory control test: 20023017-I from 29.10.2020 (BAG) type testing: 17054437 I from 29.01.2018 (BAG)
Test Basis <i>Prüfgrundlagen</i>	DIN EN ISO 5175-2 (01.03.2018)- partially (see remarks)



Date of Expiry / File No. 25.07.2024 / 21-0214-GNV
Ablaufdatum / Aktenzeichen

07.05.2021 Rie A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-05

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
339	maximum operation pressure: 3 bar	by combustion methane/air

Hints of Utilization / Remarks***Verwendungshinweise / Bemerkungen***

connection: at both sides internal thread G 1 1/2 and G 2 or flanges DN 40, DN 50

The valve is flame flow-back tight and flame blow-back proof resist for methane by combustion with air.

The testing and certification of the valve was carry out partially regarding the flame puncture resistance with a combustion gas/air mixture.