



CERT

DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NG-4390BM0275

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	WITT GmbH & Co. Holding & Handels KG Salinger Feld 4-8, D-58454 Witten
Distributor <i>Vertreiber</i>	WITT-Gasetechnik GmbH & Co. KG Salinger Feld 4-8, D-58454 Witten
Product Category <i>Produktart</i>	gas fittings: Gas back flow safety device (4390)
Product Description <i>Produktbezeichnung</i>	non-return valve with flame arrestor and temperature-sensitive cut-off valve
Model <i>Modell</i>	623 N/NU
Test Reports <i>Prüfberichte</i>	laboratory control test: 20023017-III from 29.10.2020 (BAG) type testing: 17054437 II from 05.02.2018 (BAG)
Test Basis <i>Prüfgrundlagen</i>	DIN EN ISO 5175-1 (01.03.2018)



70028-04-A-DE

Date of Expiry / File No. 16.07.2026 / 21-0214-GNV
Ablaufdatum / Aktenzeichen

07.05.2021 Rie A-1/2
Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



DVGW CERT GmbH
Zertifizierungsstelle
Josef-Wirmer-Str. 1-3
53123 Bonn
Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993
www.dvgw-cert.com
info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
623 N/NU	maximum operation pressure: 2,0 (propane); 3,5 (methane) bar	for the combustion propane/oxygen respectively methane/oxygen

Type Variation <i>Ausführungsvariante</i>	Explanations <i>Erläuterungen</i>
...N	connection: at the input side external thread G 3/4...G 1 1/4, at the outlet side connecting piece G 3/4...G 1 1/4 with union nut or at both sides connecting piece with internal thread G1
...NU	connection: at the input side connecting piece G 3/4...G 1 1/2 with union nut, at the outlet side external thread G 3/4...G 1 1/2