



CERT

DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NG-4390BN0007

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	WITT GmbH & Co. Holding & Handels KG Salinger Feld 4-8, D-58454 Witten
Distributor <i>Vertreiber</i>	WITT-Gasetechnik GmbH & Co. Produktions- und Vertriebs KG Salinger Feld 4-8, D-58454 Witten
Product Category <i>Produktart</i>	Gas fittings: Gas back flow safety device (4390)
Product Description <i>Produktbezeichnung</i>	flame puncture resistant gas back flow safety device
Model <i>Modell</i>	Modell RV 80
Test Reports <i>Prüfberichte</i>	Laboratory control test: K 21/11/3672 from 26.11.2021 (DBI)
Test Basis <i>Prüfgrundlagen</i>	DIN EN ISO 5175-1 (01.03.2018)- partially (see remarks) DIN EN ISO 5175-2 (01.03.2018)- partially (see remarks)

Date of Expiry / File No. 18.01.2027 / 22-0584-GNV
Ablaufdatum / Aktenzeichen

70028-04-4-DE

26.01.2023 Kir A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Gas Category <i>Gasart</i>	Remarks <i>Bemerkungen</i>
Natural gas	

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
Modell RV 80	Maximum operating pressure: 10 bar	

Hints of Utilization / Remarks***Verwendungshinweise / Bemerkungen***

The flame kick back safety device is flame-puncture resistant and flame-puncture safe up to maximum 8 bar at combustion with air as oxidant.

The testing and certification was done similarly to DIN EN ISO 5175-1, chapter 6.7 and DIN EN ISO 5175-2, chapter 5.7, because air was used as oxidant.

