



**CERT**

# DVGW type examination certificate

## DVGW-Baumusterprüfzertifikat

**DG-4390DO0058**

Registration Number  
Registriernummer

<b>Field of Application</b> <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
<b>Owner of Certificate</b> <i>Zertifikatinhaber</i>	WITT GmbH & Co. Holding & Handels KG Salinger Feld 4-8, D-58454 Witten
<b>Distributor</b> <i>Vertreiber</i>	WITT-Gasetechnik GmbH & Co. Produktions- und Vertriebs KG Salinger Feld 4-8, D-58454 Witten
<b>Product Category</b> <i>Produktart</i>	Gas fittings: Gas back flow safety device (4390)
<b>Product description</b> <i>Produktbezeichnung</i>	Flame-proof gas retraction protection
<b>Model</b> <i>Modell</i>	Ultra 41 mit Filter
<b>Test reports</b> <i>Prüfberichte</i>	Type testing: B 23/01/4005 from 25.01.2023 (DBI)
<b>Test basis</b> <i>Prüfgrundlagen</i>	DIN EN ISO 5175-1 (01.03.2018) DIN EN ISO 5175-2 (01.05.2019)

**Date of Expiry / File No.** 25.01.2028 / 22-0456-GNE  
*Ablaufdatum / Aktenzeichen*



22.03.2023 Kir A-1/2

Date, Issued by, Sheet, Head of Certification Body  
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



DVGW CERT GmbH  
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3  
53123 Bonn

Tel. +49 228 91 88 - 888

Fax +49 228 91 88 - 993

www.dvgw-cert.com  
info@dvgw-cert.com

<b>Gas Category</b> <i>Gasart</i>	<b>Remarks</b> <i>Bemerkungen</i>
Fuel gases according to G 260	additionally oxygen and compressed air

<b>Type</b> <i>Typ</i>	<b>Technical Data</b> <i>Technische Daten</i>	<b>Remarks</b> <i>Bemerkungen</i>
035-003; 035-010	Maximum operating pressure: 20 (CH <sub>4</sub> , C <sub>3</sub> H <sub>8</sub> , H <sub>2</sub> , O <sub>2</sub> , compressed air); 2 (CH <sub>4</sub> colbusted with air) bar	both sides G 2½" female thread
035-008; 035-009	Maximum operating pressure: 20 (CH <sub>4</sub> , C <sub>3</sub> H <sub>8</sub> , H <sub>2</sub> , O <sub>2</sub> , compressed air); 2 (CH <sub>4</sub> colbusted with air) bar	both sides NPT 2½" female thread

<b>Type Variation</b> <i>Ausführungsvariante</i>	<b>Explanations</b> <i>Erläuterungen</i>
Index 001	Stainless steel
Index 003	Brass

#### **Hints of Utilization / Remarks**

##### ***Verwendungshinweise / Bemerkungen***

MOP 20 is valid for applications with pure gases without requirements to the flashback resistance.  
MOP 2 is valid for applications with requirements to the flashback resistance.